

ELECTRICAL LEGEND

NOTES:

1. MOUNTING HEIGHTS SHALL BE TO THE CENTER OF THE DEVICE ABOVE FINISHED FLOOR UNLESS OTHERWISE NOTED.

1

DR

PROVIDE A 10"Hx8"Wx4"D RECESSED (FLUSH-MOUNTED) HOFFMAN ASE BOX FOR DORM REMOTE. INSTALL 42 INCHES ABOVE FINISHED FLOOR. PROVIDE 3/4 INCH CONDUIT IN WALL UP TO NEARBY ACCESSIBLE CEILING SPACE.

1

ST

SHUNT TRIP MECHANISM.
(SEE 'POWER DISTRIBUTION RISER DIAGRAM.)

REFER TO DRAWINGS: E-0.1

ADDENDUM REVISION

**BRAMBLETON PUBLIC SAFETY CENTER
BELMONT RIDGE ROAD
BRAMBLETON, VIRGINIA**

BIGNELL/WATKINS/HASSER ARCHITECTS
ONE PARK PLACE, SUITE 250 ANNAPOLIS, MARYLAND 21401



**SCHLENGER / PITZ
& ASSOCIATES, INC.**
Consulting Engineers

15 West Aylesbury Road, Timonium, Maryland 21093
Phone 410.561.1337
Fax 410.561.1446
WWW.SPAENGINEERS.COM
© Copyright 2011 Schlenger/Pitz & Associates, Inc.

DATE: 04/28/2011

SCALE: NOT TO SCALE

DWG. NO:

SKE-01-1